

ADDENDUM #1

TRUCK SCALE Franklin County Commission

The following shall be part of the plans and specifications for the above project as if written and show in full therein, all items not specifically changed or revised by Addenda shall remain exactly as originally required. The Contractor shall acknowledge this addendum on the form.

1. Under Section II- Bid Specifications C Scope of Work- 2a- the definition of “continuous foundations”: A single strip of concrete is poured along the perimeter to provide a stable base by evenly distributing the weight of the scale to prevent uneven settlement.
2. Under Section II- Bid Specifications C Scope of Work- 2f- The verbiage “This approach assumes existing grade to be at the top of approach elevation” is explained as the existing approaches should be adjusted to match the top elevation of new scale. The new scales will be at higher elevation so the new approaches will have to match highest elevation of new scales.
3. Under Section II- Bid Specifications C Scope of Work- 3d- To meet the requirements stated at the last sentence “in such a manner so as to limit interruption in the County’s operations” Is this statement indicating that overtime or weekend work hours will be required? Overtime or weekend work hours would be preferred, if needed, to expedite the project completion.
4. Also, will county trucks need to be weighed during construction period? Trucks will not need to be weighed at our landfill during construction.